

Notified body No.1121  
 Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

## Certificate of constancy of performance

**1121-CPR-DA5000**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### " Module Floors PVC Floor Tile "

A PVC interlocking floor tile, manufactured in the following grades:

- 4mm Industrial grade - textured finish
- 4mm Industrial grade - chequered finish
- 5mm Commercial grade - textured finish
- 5mm Commercial grade - studded finish
- 5mm Commercial grade - slate finish
- 5mm Industrial grade - textured finish
- 5mm Industrial grade - studded finish
- 7mm Industrial grade - textured finish
- 7mm Industrial grade - studded finish

**Intended use: Floorcovering**

**Product Performance**

Harmonized technical specification - EN 14041:2004 / AC:2006			
Essential characteristics	Performance	Method	Report reference
Reaction to fire	B <sub>FL</sub> -S1	EN 13501-1	Classification reports: WF 190593, WF 190594 & WF 330485 Extended application reports: WF 190595, WF 330486
Content of pentachlorophenol	NPD	Verification not required	N/A
Emission of formaldehyde	E1	Manufacturers declaration	Not used in manufacturing process
Water-tightness	NPD	EN 13553	NPD
Slipperiness	Textured - 0.50 to 0.75 Studded - 0.69 to 0.70 Slate - 0.55 to 0.57 Chequered - 0.58- to 0.61 Flat - 0.44 to 0.45	EN 13893	FL00182952/1009/1/2/3/4/5/6/7
Electrical behaviour	2.1 to 4.2	EN 1815 & EN 1081	FL00182952/1009/1
Thermal conductivity	NPD	EN 12524 / EN 12667	-

**NPD – No Performance Determined.**

**Product Specification**

## Certificate of constancy of performance

**1121-CPR-DA5000**

produced for

**R-Tek Manufacturing Ltd.  
Unit 1  
Hamiltownsbawn Industrial Estate  
Armagh  
Co. Armagh  
BT60 1HW**

and produced in the manufacturing plant

**E067**

**This number is in coded form and the information is held by the Notified Body**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN14041:2004/AC:2006**

under system 1 of AVCP are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on **07/01/14** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan  
Certification Manager  
Warrington Certification Ltd

